

Office: Executive Engineer, W/S & Sanitation Division No.1,
Hoshiarpur.

Phone/FAX No.01882-240484

email:-cewss.div1hoshiarpurpb@yahoo.com

To

The Principal,
Guru Gobind Singh Public School,
Nainowal Vaid.

No. 2221 date :-10/4/23

Sub :- **Issue Health and Sanitary condition certificate for session 2023-24**

Ref. Your application Ref. No. GGPS/Nainowal Vaid/351 dated 21.03.2023

It is pertaining to the subject cited above that the building of **Guru Gobind Singh Public School, Nainowal Vaid** has been inspected by this office and the sanitation condition is found quite satisfactory for the **year 2023-24.**

Executive Engineer,
W/S & Sanitation Divn. No.1,
Hoshiarpur.

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

To,

Guru Gobind Singh Public School
Vill. Nainowal Vaid, Tanda Road, Distt. Hoshiarpur

No.: RWTLHSP/2223/00582 Dated : 27/03/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. GGPS/Nainowal Vaid/350 Dated: 21/03/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 22/03/2023. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Hoshiarpur

D/A : Test Report



**Authorized Signatory
For, Regional Water Testing Lab, Hoshiarpur**

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwthsp@gmail.com



TEST REPORT

Name & Address of Customer : Guru Gobind Singh Public School Vill. Nainowal Vaid, Tanda Road, Distt. Hoshiarpur	Customer Reference No. No : GGPS/Nainowal Vaid/350 Dated : 21/03/2023
	Sample Submitted by Simranjit Singh
	Date of Sample Receipt 22/03/2023
	Analysis Starting Date 25/03/2023
	Analysis completion Date 27/03/2023

Discipline : Chemical Testing	Group: Water
ULR No.: TC977923000000239F	Sample Type : Water
Test Report No.: RWTLHSP/2223/00582	Date of Issue : 27/03/2023
Registration no.: RWTLHSP/REG2223/01174	Condition of Sample : Unsealed
Collection Point: Private Submersible	Quantity/Type of Bottle: 1000 ml / Amber Coloured Sample Bottle - 500 mL
Scheme/Source: Not Mentioned(Not Mentioned)	Location/Depth : Vill. Nainowal Vaid, Tanda Road, Distt. Hoshiarpur / NA
Village : Not Mentioned	Habitation : Not Mentioned
Block: Tanda	District : Hoshiarpur
Latitude : Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
2	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
3	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
4	TDS	198.0	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	142.8	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	136.0	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
8	Calcium	36.87	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	10.69	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	17.35	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

[Signature]

Mr. Jivesh Kumar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab, Hoshiarpur

End of the Test Report

REGIONAL WATER TESTING LAB, HOSHIARPUR
Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

Payment Receipt

Receipt No. : 06593

Invoice No. : INV/2223/00562

Date : 22/03/2023

Invoice Date : 22/03/2023

Received From : Guru Gobind Singh Public School
Vill. Nainowal Vaid, Tanda Road, Distt. Hoshiarpur

The Sum of Rupees : Five Hundred Seventy Nine Only.

In Cash

Rs. : 579.00

Disclaimer: -Payment made by cheque/online mode are subject to clearance by bank.

For Regional Water Testing Lab, Hoshiarpur
Authorized Signatory